



Shanghai Fang Zhan Fire Technology Co., Ltd.



0474/2019

Quality certificate for Self-contained positive pressure air breathing apparatus

Model RHZK6.8

Date 2019.3

Product No. 19268076

Air bottle No.

Performance

1	Air bottle	Capacity	6.8L
		Working pressure	30MPa
2	Pressure reducing valve	Air supply	>500L/min
		Output pressure	0.4-0.9MPa
3	Safety valve opening pressure		1.0-1.5MPa
4	Residual gas alarm pressure		5.5±0.5MPa
5	Respiratory resistance		<1000Pa

It's in compliance with the provisions of the 2000 Amendments to SOLAS 1974, Reg. II-2/10, SOLAS 1974, Reg. II-2/15, IMO Res. MSC.36(63)-(1994 HSC code), IMO Res. MSC.97(73)-(2000 HSC code) 7, MSC.98(73)-(FSS code) 3, MSC.338(91) and MSC.339(91), ISO23269-2:2011.



Surveyor

Date of inspection 2019.3

<http://www.119fz.cn>

Nº 19031123